

UL Online Certifications Directory**KDER7.E90057
Grounding and Bonding Equipment Certified for Canada**[Page Bottom](#)**Grounding and Bonding Equipment Certified for Canada**[See General Information for Grounding and Bonding Equipment Certified for Canada](#)**L H DOTTIE CO**

E90057

6131 S GARFIELD AVE
COMMERCE, CA 90040 USA

Bronze ground clamp for bare or armored wire, for making connection between bare or armored wire and galvanized water pipe. Sizes 1/2" through 4". Cat. Nos. 26, 26SWV, 28 for direct burial.

Bronze ground clamp for bare wire, for making connection between copper grounding conductor, galvanized water pipe, copper water tubing or copper ground rod. Sizes 1/2" through 6". Cat. Nos. 25, 27, 250, 1001, 1002, DB-25, -27, PL25 for direct burial.

Bronze ground pipe clamp for rigid conduit or intermediate metallic conduit, for making connection between copper grounding conductor, galvanized water pipe, copper water tubing or copper ground rod. Sizes 1/2" through 4". Cat. Nos. 29L, 30L, 31L, 270L, 271L, 272L, 280L, 281L, 290L, 291L, 292L, 29L-BB, 30L-BB, 31L-BB.

Bronze ground rod clamp for direct burial, Sizes 1/2" through 3/4". Cat. Nos. GR-12, -34, -58.

Conduit hubs, Sizes 1/2" through 1". Cat. Nos. HUB-50L, -75L, -100L.

Bronze ground pipe clamp for bare wire, for making connection between copper grounding conductor, galvanized water pipe, copper water tubing or copper ground rod. Size 1/2" through 6". Also for steel rebar sizes 5 and 6. For direct burial in earth and concrete Cat. No. DB-25.

[Last Updated on 2002-08-03](#)[Questions?](#)[Notice of Disclaimer](#)[Page Top](#)

Copyright © 2006 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2006 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

